



Office of the Chief Fire Officer,
Pune Municipal Corporation

Out W. No: FB / 4287

Date : - 02/01/2026

To,
Shalaka Foundation's
The Keystone Ankuram School,
Near Handewadi Chowk, Pune.

Certified that, the existing building of Shalaka Foundation's The Keystone Ankuram School, at Sr. No. 305/7, 306, 307/5 and 308/21, Shewalewadi, Uruli Devachi, Pune comprised of 01 Basement + 01 Ground Floor + 01 floor (One Block) building block occupied by The Keystone Ankuram School at Sr. No. 305/7, 306, 307/5 and 308/21, Shewalewadi, Uruli Devachi, Pune have complied with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire Service Rules and verified by the officers concerned of fire service on 24/12/2025 in the presence of Dr. Prashant Kasabe, Director, The Keystone Ankuram School at at Sr. No. 305/7, 306, 307/5 and 308/21, Shewalewadi, Uruli Devachi, Pune and that the building is fit for occupancy up to classes I to XII with effect from 02/01/2026 for period of one year in accordance with rule and subject to compliance of the specific conditions as appended.

1. No Compliance

Issued on 02/01/2026 at Pune by

Dwange
02/01/26
Station Duty Officer
Fire Brigade PMC, Pune



KOHINOOR
— SAFETY SERVICES —

AN ISO 9001 : 2015 CERTIFIED COMPANY

Ref: KSS /2025-26/B-611

Date: 17 January 2026

Form B

[See Section 3(3) and rule 4(2)]

Six Monthly Certificates to be given in every JAN & JULY by the owner or the occupier for Compliance of Fire prevention and life safety measures.

Certificate

Certified that I/We have carried out inspection of the fire prevention and life safety measures Installed in the following building or premises, namely:-

“THE KEYSTONE ANKURAM SCHOOL”

KEYSTONE CAMPUS

**Address :SR NO 305/7, 307/5 & 308/21, NEAR HANDEWADI CHOWK,
PUNE - 412308**

I/we further certify that these installations in the above mentioned buildings are maintained in good repair and efficient conditions during the period (1 Jan 2026 to 31 Dec 26), as required under the provision of Maharashtra Fire Prevention and Life safety Measure Act, 2006 (MAH III of 2007). The details of the inspection of the installations carried out by me / we are mentioned in the report appended herewith.

Place: Mumbai

Date: 17 January 2026

Signatories:

License Number:

1. MFS / LA / RF-25
2. MFS / LA / RD-27

KIRAN

SHRIRANG

MHASKE

Digitally signed

by KIRAN

SHRIRANG

MHASKE

Date: 2026.01.17

16:03:33 +05'30'



KOHINOOR
— SAFETY SERVICES —

AN ISO 9001 : 2015 CERTIFIED COMPANY

Ref: KSS /2025-26/B-611

Date: 17 January 2026

With reference cited above, below is the detail of firefighting system at :

“THE KEYSTONE ANKURAM SCHOOL”

KEYSTONE CAMPUS

Address : SR NO 305/7, 307/5 & 308/21, NEAR HANDEWADI CHOWK,

PUNE - 412308

Annexure for Form B:

SR. NO.	FIRE SYSTEM	QTY	REMARK
1	Hydrant Valve	4	OKAY
2	Hose Box	4	OKAY
3	CO2 Type Fire Extinguisher 4.5Kg	1	OKAY
4	Courtyard Hydrant System	1	OKAY
5	2280LPM Electric Pump	1	OKAY
6	100mm Butterfly Valve	2	OKAY
7	2 Zone Fire Alarm Panel	1	OKAY
8	Signages	1	OKAY

The above said fire Protection equipment installed in good working condition. There after any alteration in above system by occupant or developer will make this certificate invalid.

Thanking You.

License Number:

2. MFS / LA / RF-25
3. MFS / LA / RD-27

KIRAN

SHRIRANG

MHASKE

Digitally signed by
KIRAN SHRIRANG
MHASKE

Date: 2026.01.17
16:03:52 +05'30'



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666
www.mahafireservice.gov.in

FORM N
[(See section 9 (3) and rule 14]
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-25 / RD-27

Date: 14.01.2026

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Kohinoor Safety Services** having their registration office at **477, Ambedkar Soc., Puriwala, Parksite, Vikroli (W), Mumbai 400079** and their contact details are Office Number: 9892613864 and Email ID: fire.india@yahoo.com with PAN registration No. AGKPC6876C and GST No. 27AGKPC6876C to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

1. Fire Fighting and Sprinkler System: Class D
2. Detection and Fire Suppression System: Class D

M/s. Kohinoor Safety Services shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **14.01.2026 to 13.01.2028**

Santosh Warick Digitally signed
by Santosh Warick
Date: 2026.01.15
10:43:58 +05'30'

(S S Warick)
Director
MF&ES, Mumbai

License Agency Digital Sign

KIRAN SHRIRANG MHASKE Digitally signed by
KIRAN SHRIRANG
MHASKE
Date: 2026.01.14
13:29:15 +05'30'

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.