



फुरसुंगी - उरुळी देवाची नगरपरिषद

ता. हवेली जि. पुणे

✉ - fursungi.urulidevachinp2024@gmail.com



स्वातंत्र्याचा अमृत महोत्सव

क्रमांक / फुउदेनप / 3382 / २०२५ - २६

दिनांक :- १०/१२/२०२५

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

It is certificate that an inspection conducted by Mr. Prakash Tulse, Inspector, from Health Department (Sanitation) inspected The Keystone Ankuram School, having UDISE No – 27250507807, located at Sr. No. 305/7, 306, 307/5 and 308/21, Shewalewadi, Uruli Devachi, Pune – 412308 on 07/12/2025 and found that The Keystone Ankuram School has Safe Drinking Water Facilities for the students and staff member of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Maharashtra State.

The garbage generated from school is transported by municipal corporation vehicle for further disposal.

The Above certificate is issued on the demand of applicant for educational purpose.

*Tulse*  
Prakash Tulse

Sanitary Inspector



*[Signature]*  
Chief Officer

Fursungi Uruli Devachi Municipal Corporation

Ref. No. : AARI / 355 / 2025-2026

Date : 17/01/2026

**Water Analysis Report**

Applicant Details			
<b>Party Name</b>		<b>Authorized Person</b>	
The Keystone Ankuram School Sr. No.-306, Keystone Campus, Near Handewadi Chowk, Pune-412308		Dr. Prashant Kasabe	
		<b>Mobile Number</b>	
		9822347600	
		<b>Email Id.</b>	
		prashantkasabe@gmail.com	
Sample Details			
<b>Name of the Sample</b>	Drinking Water	<b>Received on</b>	12.01.2026
<b>Sample Description</b>	Particle free sample	<b>Test Started On</b>	12.01.2026
<b>Date of Mfg./ Sampling</b>	N.S.	<b>Test Completed on</b>	16.01.2026
<b>Batch No.</b>	N.S.	<b>Sample Quantity</b>	1000ml
<b>Sampling Method:</b>	N.S.	<b>Packaging Specifications</b>	Intact and Airtight

<b>Discipline</b>	Chemical and Biological Testing
<b>Type</b>	Water
<b>Temperature Condition</b>	0-8°C

Sr. No.	Test Parameters	Standard/Test Method	Test Results	Units	Requirements Specifications as per 10500:2021
1	pH	IS 3025 (Part 11) 1983 RA 2017	7.18	N.S.	6.5-8.5
2	Odour	IS 3025 (Part 05) 1983 RA 2017	Agreeable	N.S.	Agreeable
3	Turbidity	IS 3025 (Part 10) 1983 RA 2017	0.6	NTU	Max. 1
4	Total Dissolved Solids	IS 3025 (Part 16) 1983 RA 2017	55	Mg/l	Max. 500
5	Hardness	IS 3025 (Part 21) 1983 RA 2017	43.12	Mg/l	Max. 200
6	Calcium (Ca)	IS 3025 (Part 40) 1983 RA 2017	10	Mg/l	Max. 75
7	Magnesium (Mg)	IS 3025 (Part 46) 1983 RA 2017	<5	Mg/l	Max. 30

Page 1 of 2




8	Sulphate (SO <sub>4</sub> )	IS 3025 (Part 24) 1983 RA 2017	<5	Mg/l	Max. 200
9	Alkalinity (CaCO <sub>3</sub> )	IS 3025 (Part 23) 1983 RA 2017	26.58	Mg/l	Max. 200
10	Chlorides (Cl)	IS 3025 (Part 32) 1983 RA 2017	5.3	Mg/l	Max. 250
11	Total Bacterial Count	IS 1622: 1981 RA 2019	41	Cfu/ml	N.S.
12	Coliform	IS 1622: 1981 RA 2019	<2	MPN/100ml	Absent
13	E-Coli	IS 1622: 1981 RA 2019	Absent	Per /100ml	Absent


N.S.: Not Specified

**Analysis Remark:**

As per above specifications (ISO 10500:2021) sample **passes** for tests conducted and suitable for drinking purpose.

  
Analyst Signatory  
(Chemical and Microbiological)  
**Analyst**  
(Chemical & Microbiological)



  
Authorized Signatory  
(Director)  
**ASTER ANALYTICS RESEARCH  
INSTITUTE, PUNE**

Released By	
Date	16/01/2026
Sign	

Verified By
Date: 16/01/2026
Sign: 

1. The results contained in this test report relate to the sample received and tested by laboratory.
2. Sampling was not done by ASTER ANALYTICS RESEARCH INSTITUTE, PUNE.
3. This report, in full or part, shall not be published or used by any means for advertisement without written approval of the laboratory.
4. Sample/s will be retained by us for a period of 2 weeks after test completed date (working days) for non-perishable items only. Perishable items will be destroyed after completion of test.

\*\*\*End of Report\*\*\*